

# F-01 Practice Test Questions and Answers

**1. What type of fire suppression system uses water as the primary extinguishing agent?**

- A) Sprinkler system
- B) CO2 system
- C) Halon system
- D) Dry chemical system

**2. Which NFPA standard covers the installation of sprinkler systems?**

- A) NFPA 10
- B) NFPA 13
- C) NFPA 25
- D) NFPA 72

**3. At what temperature do standard sprinkler heads typically activate?**

- A) 135°F - 170°F
- B) 200°F - 250°F
- C) 300°F - 350°F
- D) 400°F - 450°F

**4. What is the minimum water pressure required for most sprinkler systems?**

- A) 5 PSI
- B) 7 PSI
- C) 10 PSI
- D) 15 PSI

Answers: 1-A 2-B 3-A 4-B

For More F-01 Questions and Answers FREE, F-01 Online Prep Training, F-01 Exam, F-01 Study Guide, F-01 Flashcards, F-01 Quizzes visit:

## F-01 Practice Test